

# ENERGY GUIDE



This guide will help you compare the annual operating costs of the **UNICOSYSTEM** and a conventional system. The Unico Energy Guide is based on the *ARI Guide for Estimating Annual Operating Cost of a Central Air Conditioner or Heat Pump* in the printed forward of the ARI Unitary Directory. The ARI Guide estimates the equipment operating cost based on geographical location and local utility rates. It is a good method for comparing similar systems. Unfortunately, the ARI procedure does not include the type of duct used, installation quality, or comfort level. These additional factors are extremely important when comparing two dissimilar systems such as the **UNICOSYSTEM** and a conventional system. The Unico Energy Guide follows the same methodology but also accounts for the type of distribution system and the comfort of the occupants.

In most cases, when comfort and duct design is included in the operating cost, the Unico cooling system will cost marginally more to operate on an annual basis — on the order of less than \$10 per year. This makes the benefits of the **UNICOSYSTEM** very attractive. The Unico heat pump, on the other hand, will cost less to operate than a conventional system when comfort is included as part of the analysis. The Unico heat pump can cost as much as 10% less to operate, depending on which region you are in.

## STEP-BY-STEP PROCEDURE

The following is a step-by-step procedure for estimating the annual operating costs of your **UNICOSYSTEM** and for comparing this cost to a conventional system designed to deliver you the same level of comfort you expect from your **UNICOSYSTEM**. This procedure is based on the ARI Energy Guide and requires the efficiency and capacity ratings listed in the ARI Unitary Directory in addition to your local heating and cooling load hours and utility rates.

DISCLAIMER (Our lawyers make us do this.) Estimates of operating costs may be higher or lower than your average operating costs. They are affected by many factors that can vary widely. For example, since no two heating or cooling seasons are identical, operating costs will vary from year-to-year. Operating costs are also affected by the temperature that is to be maintained — the thermostat setting — with higher settings costing more in winter and lower settings costing more in summer. Other factors that affect system operation include the number of occupants, location within a region, activities that generate or release heat with the structure, and living habits such as the opening of windows, etc. Nevertheless, the estimates will be helpful in determining approximately how much a system will cost to operate and to compare the performance of different systems.

## Completed Sample Worksheet

**A. The Building**

1. Location
2. Outdoor Design Temperature
3. Local Power Rates
4. Load Hours (Fig. 1 and 2)

<b>St. Louis, Missouri (Region IV)</b>		
	°F	a) Summer <b>94°F DB / 75°F WB</b>
	b) Winter	<b>8°F</b>
	\$/kW-hr	a) Summer <b>0.0831</b>
	\$/kW-hr	b) Winter <b>0.0750</b>
	Hour	a) Summer <b>1100</b>
	Hour	b) Winter <b>2000</b>

**Type of System**

Conventional System	Unico System
---------------------	--------------

**B. Summer (Cooling) Load**

1. Indoor Design Temperature
2. Building Heat Gain
3. Duct Loss
4. Duct Heat Gain
5. Total Heat Gain

	°F	<b>75</b>	<b>78</b>
	Btu/hr	<b>40,000</b>	<b>34,000</b>
	%	<b>15<sup>1</sup></b>	<b>8<sup>2</sup></b>
	Btu/hr	<b>6,000</b>	<b>2,720</b>
	Btu/hr	<b>46,000</b>	<b>36,720</b>

**C. Winter (Heating) Load**

1. Indoor Design Temperature
2. Building Heat Loss
3. Duct Loss
4. Duct Heat Loss
5. Total Heat Loss

	°F	<b>72</b>	
	Btu/hr	<b>60,000</b>	
	%	<b>20</b>	<b>12</b>
	Btu/hr	<b>12,000</b>	<b>7,200</b>
	Btu/hr	<b>72,000</b>	<b>67,200</b>

**D. Equipment Data from ARI Directory**

1. Outdoor Equipment
2. Indoor Equipment
3. Rated Unit Cooling Capacity
4. Rated Cooling Efficiency, SEER
5. Rated Unit Heating Capacity
6. Rated Heating Efficiency, HSPF
7. Average Heating Annual Operating Cost

<b>Trane 4TWX4048A1</b>		
	<b>4TTE3F49A</b>	<b>MB4860L + MC4860HX</b>
	Btu/hr	<b>50,500</b>
	Btu/h/W	<b>14.0</b>
	Btu/hr	<b>45,000</b>
	Btu/h/W	<b>8.45</b>
	\$	<b>815</b>

**E. Calculate Estimated Cooling Cost**

1. Cooling Cost = (B.5)(A.3a)(A.4a)/((1000)(D.4))

	\$	<b>300</b>	<b>305</b>
--	----	------------	------------

**F. Calculate Estimated Heating Cost**

1. Conventional Heating Cost Factor<sup>3</sup> (Table 1)
2. UnicoSystem Heating Cost Factor (Table 2)
3. Heating Cost = (A.3b)(A.4b)(D.7)(F.1)/((2080)(0.0831<sup>4</sup>))
4. Heating Cost = (A.3b)(A.4b)(D.7)(F.2)/((2080)(0.0831<sup>4</sup>))

		<b>2.291</b>	
			<b>1.804</b>
	\$	<b>1620</b>	
	\$		<b>1232</b>

In this example, the Unico System will cost approximately \$5 dollars more per year to cool the residence but will save \$388 to heat per year for a total energy savings of \$383.

<sup>1</sup> Ref: Florida Energy Report average home thermal losses for duct in non-conditioned air space, 1985.

<sup>2</sup> Ref: Dunham-Bush internal company test report, 1976.

<sup>3</sup> With a comfort controller added to maintain a constant discharge temperature of 100°F




Figure 1. Cooling Load Hours




Figure 2. Heating Load Hours

Table 1. Heating Cost Factor for Conventional System with Electric Comfort Controller  
(Maintains 100°F air temperature)

Range of Comparability, Btu/hr		Building Heat Loss, MBtu/hr (MBtu/hr times 1000 = Btu/hr)																
		5	10	15	20	25	30	35	40	50	60	70	80	90	100	110	130	
Up to 12,499	Region I	0.598	1.118	1.607														
	Region II	0.694	1.302	1.850	2.444													
	Region III	0.771	1.452	2.066	2.677													
	Region IV		1.646	2.336	3.015	3.773												
	Region V		1.860	2.639	3.386	4.193												
	Region VI	0.656	1.234	1.753	2.304													
12,500-17,499	Region I	0.408	0.779	1.118	1.442													
	Region II	0.473	0.905	1.302	1.670	2.037												
	Region III		1.007	1.452	1.866	2.264	2.677											
	Region IV		1.141	1.646	2.113	2.557	3.015	3.503	4.045									
	Region V		1.291	1.860	2.388	2.886	3.386	3.913	4.479									
	Region VI	0.447	0.856	1.234	1.583	1.927	2.304	2.726										
17,500-22,499	Region I		0.598	0.867	1.118	1.359												
	Region II		0.694	1.007	1.302	1.580	1.850											
	Region III			1.122	1.452	1.765	2.066	2.366	2.677									
	Region IV			1.271	1.646	1.999	2.336	2.670	3.015	3.772								
	Region V			1.437	1.860	2.260	2.639	3.009	3.386	4.193	5.081							
	Region VI		0.656	0.954	1.233	1.498	1.753	2.016	2.304									
22,500-27,499	Region I		0.485	0.708	0.918	1.118	1.312											
	Region II			0.822	1.068	1.302	1.525	1.742	1.962									
	Region III			0.914	1.189	1.452	1.704	1.947	2.185	2.677								
	Region IV				1.348	1.646	1.930	2.203	2.469	3.015	3.608							
	Region V				1.524	1.860	2.182	2.489	2.787	3.386	4.025	4.718	5.466					
	Region VI		0.777	1.011	1.233	1.446	1.651	1.855										
27,500-32,499	Region I			0.598	0.779	0.952	1.118											
	Region II			0.694	0.905	1.108	1.302	1.489	1.670									
	Region III			0.771	1.007	1.234	1.452	1.663	1.866	2.264								
	Region IV				1.141	1.398	1.646	1.883	2.113	2.557	3.015							
	Region V				1.291	1.581	1.860	2.129	2.388	2.886	3.386	3.913	4.479					
	Region VI			0.656	0.856	1.049	1.233	1.411	1.583	1.927	2.304							
32,500-37,499	Region I			0.518	0.677	0.829	0.976	1.118										
	Region II			0.785	0.964	1.136	1.302	1.463	1.773									
	Region III				0.873	1.073	1.266	1.452	1.633	1.981	2.322							
	Region IV					1.216	1.434	1.646	1.850	2.241	2.621	3.015	3.433	3.889				
	Region V					1.375	1.622	1.860	2.091	2.532	2.956	3.386	3.837	4.313				
	Region VI				0.743	0.912	1.076	1.233	1.386	1.681	1.978							
37,500-44,999	Region I			0.445	0.583	0.716	0.845	0.970	1.091									
	Region II				0.831	0.982	1.128	1.270	1.543	1.806								
	Region III					1.093	1.257	1.417	1.723	2.017								
	Region IV						1.425	1.605	1.952	2.281	2.604	2.937	3.286	3.657				
	Region V						1.611	1.815	2.206	2.578	2.938	3.300	3.680	4.076	4.490			
	Region VI				0.786	0.930	1.069	1.203	1.462	1.712	1.965	2.235						
45,000-49,999	Region I			0.507	0.624	0.738	0.849	0.957										
	Region II				0.724	0.857	0.987	1.113	1.356	1.587								
	Region III					0.954	1.099	1.240	1.513	1.773	2.025	2.275						
	Region IV							1.405	1.714	2.008	2.291	2.569	2.853	3.149	3.461			
	Region V							1.589	1.938	2.270	2.588	2.898	3.211	3.532	3.867	4.584		
	Region VI				0.685	0.811	0.934	1.054	1.284	1.505	1.719	1.937	2.164	2.422	2.687	3.317		
50,000-54,999	Region I					0.678	0.781	0.881	1.074									
	Region II					0.787	0.907	1.024	1.250	1.466	1.674							
	Region III						1.009	1.140	1.394	1.637	1.870	2.099	2.327					
	Region IV							1.579	1.854	2.117	2.373	2.627	2.887	3.155				
	Region V								1.786	2.096	2.393	2.680	2.963	3.247	3.540	4.162		
	Region VI					0.745	0.858	0.969	1.184	1.389	1.587	1.781	1.982	2.191	2.426	2.948		
55,000-59,999	Region I				0.523	0.620	0.714	0.807	0.985									
	Region II						0.829	0.937	1.146	1.346	1.539							
	Region III								1.043	1.277	1.502	1.719	1.929	2.136				
	Region IV									1.447	1.702	1.947	2.183	2.413	2.645	2.881		
	Region V									1.636	1.924	2.201	2.467	2.725	2.981	3.240	3.783	
	Region VI						0.785	0.887	1.085	1.276	1.458	1.636	1.812	1.997				
60,000-64,999	Region I				0.486	0.577	0.666	0.752	0.920	1.082								
	Region II						0.773	0.874	1.070	1.259	1.441	1.616						
	Region III									1.192	1.404	1.608	1.806	1.999	2.191			
	Region IV										1.591	1.822	2.045	2.261	2.475	2.689	3.133	
	Region V										1.799	2.060	2.312	2.555	2.794	3.030	3.517	
	Region VI						0.731	0.827	1.013	1.193	1.365	1.532	1.696	1.859				

Table 2. Heating Cost Factor for Unico System

Range of Comparability, Btu/hr		Building Heat Loss, MBtu/hr (MBtu/hr times 1000 = Btu/hr)															
		5	10	15	20	25	30	35	40	50	60	70	80	90	100	110	130
Up to 12,499	Region I	0.440	0.842	1.352													
	Region II	0.463	0.876	1.388	2.038												
	Region III	0.486	0.920	1.419	2.063												
	Region IV		1.000	1.555	2.250	3.050											
	Region V		1.145	1.767	2.495	3.308											
	Region VI	0.454	0.852	1.315	1.922												
12,500-17,499	Region I	0.302	0.573	0.842	1.164												
	Region II	0.318	0.601	0.876	1.194	1.585											
	Region III		0.633	0.920	1.232	1.612	2.063										
	Region IV		0.682	1.000	1.355	1.766	2.250	2.776	3.323								
	Region V		0.774	1.145	1.551	1.998	2.495	3.030	3.585								
	Region VI	0.311	0.590	0.852	1.149	1.500	1.922	2.339									
17,500-22,499	Region I		0.440	0.638	0.842	1.075											
	Region II		0.463	0.669	0.876	1.112	1.388										
	Region III			0.704	0.920	1.152	1.419	1.718	2.063								
	Region IV			0.76	1.000	1.262	1.555	1.879	2.250	3.049							
	Region V			0.864	1.145	1.445	1.767	2.113	2.495	3.308	4.175						
	Region VI		0.454	0.657	0.852	1.064	1.315	1.606	1.922								
22,500-27,499	Region I		0.358	0.520	0.677	0.842	1.029										
	Region II			0.547	0.709	0.876	1.063	1.269	1.507								
	Region III			0.575	0.747	0.920	1.103	1.303	1.535	2.063							
	Region IV				0.807	1.000	1.206	1.428	1.682	2.25	2.885						
	Region V				0.919	1.145	1.383	1.635	1.906	2.495	3.141	3.821	4.529				
	Region VI			0.537	0.696	0.852	1.022	1.216	1.415								
27,500-32,499	Region I		0.440	0.573	0.705	0.842											
	Region II			0.463	0.601	0.736	0.876	1.030	1.194								
	Region III			0.486	0.633	0.775	0.920	1.070	1.232	1.612							
	Region IV				0.682	0.839	1.000	1.169	1.355	1.766	2.250						
	Region V				0.774	0.957	1.145	1.344	1.551	1.998	2.495	3.030	3.585				
	Region VI			0.454	0.590	0.722	0.852	0.994	1.149	1.500	1.922						
32,500-37,499	Region I			0.382	0.498	0.610	0.725	0.842									
	Region II				0.523	0.640	0.755	0.876	1.006	1.303							
	Region III				0.550	0.674	0.796	0.920	1.047	1.336	1.668						
	Region IV					0.727	0.862	1.000	1.145	1.464	1.826	2.250	2.697	3.167			
	Region V					0.826	0.984	1.145	1.315	1.671	2.064	2.495	2.951	3.426			
	Region VI					0.514	0.628	0.741	0.852	0.974	1.244	1.561					
37,500-44,999	Region I			0.328	0.428	0.525	0.621	0.718	0.818								
	Region II					0.552	0.65	0.749	0.851	1.075	1.335						
	Region III						0.685	0.789	0.893	1.115	1.367						
	Region IV							0.854	0.970	1.221	1.498	1.804	2.161	2.527	2.926		
	Region V							0.975	1.110	1.398	1.705	2.041	2.403	2.779	3.183	3.586	
	Region VI					0.542	0.639	0.734	0.829	1.032	1.271	1.539	1.847				
45,000-49,999	Region I				0.375	0.461	0.544	0.627	0.711								
	Region II					0.485	0.572	0.657	0.743	0.920	1.124						
	Region III						0.601	0.692	0.782	0.965	1.163	1.387	1.630				
	Region IV								0.847	1.053	1.276	1.52	1.786	2.092	2.402	2.744	
	Region V								0.966	1.207	1.460	1.729	2.020	2.332	2.652	2.998	3.705
	Region VI					0.476	0.562	0.646	0.728	0.896	1.076	1.288	1.521	1.788	2.052	2.315	2.907
50,000-54,999	Region I						0.497	0.572	0.647	0.803							
	Region II						0.523	0.601	0.678	0.835	1.006	1.193					
	Region III							0.632	0.714	0.877	1.046	1.231	1.446	1.667			
	Region IV									0.952	1.144	1.354	1.584	1.825	2.108	2.389	
	Region V									1.09	1.315	1.55	1.799	2.062	2.348	2.638	3.266
	Region VI						0.513	0.59	0.666	0.815	0.973	1.148	1.338	1.56	1.801	2.041	2.514
55,000-59,999	Region I					0.387	0.457	0.527	0.595	0.734							
	Region II							0.553	0.624	0.765	0.912	1.079					
	Region III								0.657	0.806	0.957	1.119	1.291	1.494			
	Region IV									0.873	1.043	1.225	1.417	1.636	1.861	2.119	
	Region V									0.997	1.196	1.402	1.623	1.856	2.096	2.360	2.907
	Region VI						0.543	0.613	0.750	0.889	1.035	1.206	1.378	1.591			
60,000-64,999	Region I				0.358	0.424	0.488	0.552	0.677	0.809							
	Region II							0.514	0.58	0.709	0.842	0.983	1.141				
	Region III									0.747	0.884	1.024	1.181	1.349	1.535		
	Region IV										0.960	1.122	1.295	1.479	1.681	1.894	2.367
	Region V										1.099	1.288	1.483	1.685	1.906	2.128	2.616
	Region VI								0.504	0.569	0.696	0.821	0.954	1.094	1.255	1.414	

Table 3. Heating Cost Factor for Conventional System (Reference ONLY. Compares to Table in ARI Unitary Directory)

Range of Comparability, Btu/hr		Building Heat Loss, MBtu/hr (MBtu/hr times 1000 = Btu/hr)															
		5	10	15	20	25	30	35	40	50	60	70	80	90	100	110	130
Up to 12,499	Region I	0.428	0.827	1.383													
	Region II	0.453	0.863	1.421	2.169												
	Region III	0.477	0.91	1.449	2.189												
	Region IV		1	1.612	2.42	3.372											
	Region V		1.171	1.87	2.721	3.69											
	Region VI	0.443	0.834	1.327	2.019												
12,500-17,499	Region I	0.293	0.557	0.827	1.173												
	Region II	0.311	0.587	0.863	1.202	1.644											
	Region III		0.621	0.91	1.241	1.666	2.189										
	Region IV		0.672	1	1.386	1.853	2.42	3.045	3.698								
	Region V		0.774	1.171	1.624	2.138	2.721	3.358	4.021								
	Region VI	0.303	0.575	0.834	1.145	1.533	2.019	2.498									
17,500-22,499	Region I		0.428	0.621	0.827	1.075											
	Region II		0.453	0.653	0.863	1.114	1.421										
	Region III			0.692	0.91	1.154	1.449	1.788	2.189								
	Region IV			0.751	1	1.284	1.612	1.984	2.42	3.372							
	Region V			0.869	1.171	1.503	1.87	2.27	2.721	3.689	4.733						
	Region VI		0.443	0.64	0.834	1.053	1.327	1.655	2.019								
22,500-27,499	Region I		0.348	0.505	0.659	0.827	1.026										
	Region II			0.534	0.694	0.863	1.061	1.287	1.555								
	Region III			0.563	0.734	0.91	1.102	1.318	1.58	2.189							
	Region IV				0.798	1	1.222	1.467	1.757	2.42	3.175						
	Region V				0.927	1.171	1.434	1.719	2.031	2.721	3.49	4.306	5.159				
	Region VI			0.523	0.679	0.834	1.009	1.218	1.436								
27,500-32,499	Region I			0.428	0.557	0.687	0.827										
	Region II			0.453	0.587	0.721	0.863	1.025	1.202								
	Region III			0.477	0.621	0.763	0.91	1.067	1.241	1.666							
	Region IV			0.672	0.832	1	1.181	1.386	1.853	2.42							
	Region V				0.774	0.967	1.171	1.39	1.624	2.138	2.721	3.358	4.021				
	Region VI			0.443	0.575	0.704	0.834	0.98	1.145	1.533	2.019						
32,500-37,499	Region I			0.371	0.483	0.594	0.708	0.827									
	Region II				0.511	0.625	0.739	0.863	0.999	1.325							
	Region III				0.539	0.661	0.783	0.91	1.042	1.356	1.73						
	Region IV					0.717	0.856	1	1.155	1.508	1.922	2.42	2.951	3.511			
	Region V					0.828	0.996	1.171	1.359	1.76	2.214	2.721	3.263	3.831			
	Region VI				0.501	0.613	0.723	0.834	0.959	1.249	1.603						
37,500-44,999	Region I			0.319	0.417	0.511	0.605	0.702	0.804								
	Region II				0.54	0.637	0.734	0.838	1.076	1.364							
	Region III					0.674	0.778	0.884	1.117	1.393							
	Region IV						0.849	0.97	1.24	1.55	1.901	2.321	2.754	3.231			
	Region V						0.988	1.135	1.453	1.802	2.191	2.618	3.063	3.548	4.031		
	Region VI					0.529	0.624	0.718	0.812	1.022	1.281	1.582	1.936				
45,000-49,999	Region I				0.363	0.446	0.527	0.608	0.692								
	Region II					0.472	0.557	0.64	0.724	0.905	1.123						
	Region III						0.588	0.677	0.767	0.953	1.163	1.408	1.681				
	Region IV							0.837	1.053	1.294	1.567	1.87	2.227	2.591	2.996		
	Region V							0.974	1.235	1.516	1.82	2.156	2.52	2.896	3.307	4.152	
	Region VI					0.462	0.546	0.627	0.708	0.876	1.063	1.292	1.552	1.858	2.161	2.462	3.155
50,000-54,999	Region I						0.484	0.558	0.631	0.789							
	Region II						0.512	0.589	0.665	0.823	1.001	1.205					
	Region III							0.622	0.703	0.868	1.044	1.243	1.484	1.734			
	Region IV								0.952	1.157	1.389	1.65	1.926	2.259	2.591		
	Region V									1.114	1.362	1.627	1.913	2.218	2.555	2.898	3.65
	Region VI					0.502	0.577	0.651	0.799	0.961	1.147	1.355	1.607	1.885	2.161	2.708	
55,000-59,999	Region I					0.375	0.443	0.51	0.577	0.715							
	Region II							0.539	0.608	0.746	0.897	1.075					
	Region III								0.643	0.791	0.945	1.116	1.301	1.528			
	Region IV									0.865	1.043	1.239	1.451	1.7	1.958	2.26	
	Region V									1.008	1.224	1.451	1.7	1.968	2.245	2.554	3.201
	Region VI							0.528	0.596	0.73	0.869	1.02	1.204	1.392	1.633		
60,000-64,999	Region I					0.349	0.413	0.476	0.537	0.661	0.795						
	Region II							0.503	0.567	0.695	0.83	0.977	1.148				
	Region III									0.736	0.875	1.02	1.188	1.374	1.583		
	Region IV										0.96	1.133	1.324	1.529	1.761	2.007	2.565
	Region V										1.123	1.332	1.55	1.78	2.036	2.293	2.871
	Region VI							0.493	0.556	0.68	0.805	0.941	1.089	1.265	1.439		

## Sample Worksheet

**A. The Building**

1. Location
2. Outdoor Design Temperature
3. Local Power Rates
4. Load Hours (Fig. 1 and 2)

	°F	a) Summer					
		b) Winter					
	\$/kW-hr	a) Summer					
	\$/kW-hr	b) Winter					
	Hour	a) Summer					
	Hour	b) Winter					

**Type of System**

**B. Summer (Cooling) Load**

1. Indoor Design Temperature
2. Building Heat Gain
3. Duct Loss
4. Duct Heat Gain
5. Total Heat Gain

		<b>Conventional System</b>		<b>Unico System</b>			
	°F						
	Btu/hr						
	%	<b>15<sup>4</sup></b>		<b>8<sup>5</sup></b>			
	Btu/hr						
	Btu/hr						

**C. Winter (Heating) Load**

1. Indoor Design Temperature
2. Building Heat Loss
3. Duct Loss
4. Duct Heat Loss
5. Total Heat Loss

	°F	<b>72</b>	
	Btu/hr		
	%	<b>20</b>	<b>12</b>
	Btu/hr		
	Btu/hr		

**D. Equipment Data from ARI Directory**

1. Outdoor Equipment
2. Indoor Equipment
3. Rated Unit Cooling Capacity
4. Rated Cooling Efficiency, SEER
5. Rated Unit Heating Capacity
6. Rated Heating Efficiency, HSPF
7. Average Heating Annual Operating Cost

	Btu/hr						
	Btuh/W						
	Btu/hr						
	Btuh/W						
	\$						

**E. Calculate Estimated Cooling Cost**

1. Cooling Cost = (B.5)(A.3a)(A.4a)/((1000)(D.4))

	\$						

**F. Calculate Estimated Heating Cost**

1. Conventional Heating Cost Factor<sup>6</sup> (Table 1)
2. UnicoSystem Heating Cost Factor (Table 2)
3. Heating Cost = (A.3b)(A.4b)(D.7)(F.1)/((2080)(0.0831<sup>7</sup>))
4. Heating Cost = (A.3b)(A.4b)(D.7)(F.2)/((2080)(0.0831<sup>8</sup>))

	\$						
	\$						

<sup>4</sup> Ref: Florida Energy Report average home thermal losses for duct in non-conditioned air space, 1985.

<sup>5</sup> Ref: Dunham-Bush internal company test report, 1976.

<sup>6</sup> With a comfort controller added to maintain a constant discharge temperature of 100°F

<sup>7</sup> 1997 national average.